

# NAGAR PANCHAYAT BHIKHIWIND


Ref. No. 327

Date: 31-8-2023

## SANITATION CERTIFICATE

It is certify that Guru Nanak Dev DAV Public School, Bhikhiwind has provided sanitary arrangement in good condition, has safe drinking water facilities for the students and the staff members, is maintaining the hygienic sanitation condition in the school building & the campus as per the norms & is fit for the purpose of running this School in the public health point of view.

This is certificate is issuing on the base of written request from Guru Nanak Dev DAV Public School, Bhikhiwind and personnel findings on inspection by the under signed on 31-8-2023

  
Executive Officer

Nagar Panchayat Bhikhiwind

# DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.  
dwtl1@gmail.com


## TEST REPORT

Name & Address of Customer : Guru Nanak Dev DAV Public School Bhikhiwind , Tarn Taran	Customer Reference No.	No : 11739 Dated : 28/08/2023
	Sample Submitted by	Mr. Pardeep Kumar
	Date of Sample Receipt	29/08/2023
	Analysis Starting Date	29/08/2023
	Analysis completion Date	30/08/2023
Discipline : Chemical Testing		Group: Water
ULR No.:	TC103872300000218F	Sample Type : Water
Test Report No.:	DWTLTT/2324/00142	Date of Issue : 30/08/2023
Registration no.:	DWTLTT/REG2324/00290	Condition of Sample : Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : Khemkaran Road / 400 ft
Village :	Bhikhiwind	Habitation : Bhikhiwind
Block:	Bhikhi Wind	District : Tarn Taran
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.95	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	260	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.02	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	200	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	120	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	33.66	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	8.75	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	19.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

  
 Mr. Pankaj Kumar  
 Quality Manager  
 Authorized Signatory  
 For, District Water Testing Laboratory  
 Tarn Taran

End of the Test Report