



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT


Not for legal use


Ref. No. & Date :- No 1032 dated 18.03.2024
 Issued to :- The Principal
 :- D.A.V. Model School
 :- Sector - 15 - A, Chandigarh
 Quantity of sample :- Approximate 1200 ml.
 Date of Collection :- 21-03-2024
 Client reference :- Sample Collected by Laboratory Staff
 Packing of sample :- Sample Filled in P.P. and Glass Bottle
 Source of sample :- from School tap of D.A.V. Model School
 Sector- 15 - A, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.73
2	Turbidity	< 1.0	mg/l	0.8
3	Residual Chlorine	0.2 - 0.4	mg/l	0.2
4	Total Alkalinity (as CaCO ₃)	< 200	mg/l	90
5	Total Hardness (as CaCO ₃)	< 200	mg/l	74
6	Chloride (as Cl)	< 250	mg/l	04
7	Free & Saline Ammonia	Nil	mg/l	NIL
8	Total Dissolved Solids	< 500	mg/l	132
9	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.03/2023-24/183673, dated 20.03.2024, Amount Rs.3300/-
 Note:- Water is fit for drinking


Lab No.- MCPHL/24/ 1114
 Dated:- 23.03.2024



 Chemist
 M.C.P.H. Laboratory
 Chandigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh
 Dated :-

Endst No. MCPH/24/.....
 Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
 For Information Please.


 Principal
 D.A.V. MODEL SCHOOL
 Sector 15-A, CHD
 Chandigarh


 Chemist
 M.C.P.H. Laboratory
 Chandigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)


(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2024/ 6581


Dated:- 27/5/24

It is certified that an inspection team headed by Sh. Rakesh Kumar, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the DAV Model School, Sector-15 A, Chandigarh, on 19.04.2024 and mentioned in inspection report that DAV Model School, Sector- 15 A, Chandigarh, is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. This certificate is issued with the prior approval of competent authority, Municipal Corporation Chandigarh.

The above Certificate is valid for a period of One year w.e.f 19.04.2025 (i.e Water Sampling Date).


Medical Officer of Health
Municipal Corporation
Chandigarh

To,


DAV Model School,
Sector- 15 A,
Chandigarh.



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT


Not for legal use


Ref. No. & Date :- No 1032 dated 18.03.2024
 Issued to :- The Principal
 :- D.A.V. Model School
 :- Sector - 15 - A, Chandigarh
 Quantity of sample :- Approximate 1200 ml.
 Date of Collection :- 21-03-2024
 Client reference :- Sample Collected by Laboratory Staff
 Packing of sample :- Sample Filled in P.P. and Glass Bottle
 Source of sample :- from School tap of D.A.V. Model School
 Sector- 15 - A, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.73
2	Turbidity	< 1.0	mg/l	0.8
3	Residual Chlorine	0.2 - 0.4	mg/l	0.2
4	Total Alkalinity (as CaCO ₃)	< 200	mg/l	90
5	Total Hardness (as CaCO ₃)	< 200	mg/l	74
6	Chloride (as Cl)	< 250	mg/l	04
7	Free & Saline Ammonia	Nil	mg/l	NIL
8	Total Dissolved Solids	< 500	mg/l	132
9	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.03/2023-24/183673, dated 20.03.2024, Amount Rs.3300/-
 Note:- Water is fit for drinking


Lab No.- MCPHL/24/ 1114
 Dated:- 23.03.2024



 Chemist
 M.C.P.H. Laboratory
 Chandigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh
 Dated :-

Endst No. MCPH/24/.....
 Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
 For Information Please.


 Principal
 D.A.V. MODEL SCHOOL
 Sector 15-A, CHD
 Chandigarh


 Chemist
 M.C.P.H. Laboratory
 Chandigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh